

GENSETS AT HICKMANS

LOCATION	Arlington north	UNIT #	AN-1	GENSET#	12	between 13 and process plant
ENG. INFO	DETROIT					GEN INFO KATOLIGHT
SER #	06R0977664					SER. # 695543-01-08
MOD. #	S-60					MOD. #
S.O. #						VOLTS
REF. #						AMPS
FILTER INFO						
AIR	OIL	FUEL	WATER		LAST OIL SERVICE	12/1/15
542114	1971 X 2	3118	n/a		HOURS	477
		3120				
BATTERY INFO		2-8D	LAST BATTERY SWAP OUT			12/7/15
ENG. OIL CAP.	8 GALS.	PLUS 1 gal. oil additive				
COOLANT CAP.	11 GALS.					

[illegible]